



**MATERIAL LIST**

No.	DESCRIPTIONS	MATERIAL	Q'TY	REMARKS
1	CASING	FC200	1	
2	NOZZLE	RIGID PVC	1	
3	SIGHT GLASS	CLEAR PVC	3	
4	PACKING	CNR	3	
5	FIT UP STAND	AC2B	1	
6	"O"RING	NBR	1	
7	COVER	ACRYL	1	
8	"O"RING	NBR	1	
9	BASKET	CLEAR PVC	1	
10	SCREW	C3604BD	1	
11	DIAL	C3604BD	1	
12	"O"RING	NBR	1	
13	STOP RING	SUS304	1	
14				
15				
16				
17	SPRING	SPECIAL ALLOY	1	
18	PLATE	RIGID PVC	1set	
19	SPRING	SPECIAL ALLOY	1	
20	PLATE	C2801P	1set	
21	MAGNET	SPECIAL ALLOY	1	
22	PLATE	C2801P	1	
23	REED SWITCH		1	
24	SUPPORTER	PVC	1	
25	PIPE	C3604BD	1	
26	"O"RING	NBR	1	
27	TERMINAL	NYLON 66	1	
28	PLATE	C2801P	1	
29	COVER	CLEAR ACRYL	1	
30	SCREWS	C3604BD	1	
31	PLUG	FC200	1	
32	SCREWS	SUS304	1set	

**DESIGNING OUTLINE** TEMP. +5~+60°C

NOMINAL DIAMETER	A	LIQUID	
FLOW DIRECTION	DOWNWARD	RATING (RESISTIVE)	AC200V 0.3A AC100V 0.6A DC 100V 0.6A DC 50V 0.6A DC 24V 0.6A
FLOW RATE	1/min	QUANTITY FORM	SPDT.(1c)
SET POINT (INCREASE)	1/min	COLOUR (MUNSELL)	■ 7.5BG4/1.5 □
SET POINT (DECREASE)	1/min	ACCESSORIES	■ FLANGES ■ BOLTS ■ PACKINGS

Confirm non-leakage from internal element when fill casing up with water. But the pressure of the casing is 0.2MPa.  
 ■ : APPLICABLE MARK

**FLOW RELAY MODEL LF-B1**  
PAT No.525884

NTS	Y.K	K.N	
SCALE	DRAWN	ISSUED	APPROVED

AROMANIKKI CO.,Ltd